

7. EN-SUITE FACILITIES

7.1 Is the bathroom door equal in width to the bedroom door? Yes No
Comments _____

7.2 Is there an unobstructed clear floor area of a minimum of 1500mm x 1500mm. Yes No
Comments _____

7.3 If the bathroom door is inward opening, does the door impede the 1500mm x 1500mm clear floor area? Yes No
Comments _____

7.4 Is a bath provided, and does it have adequate grab rails to assist a variety of users? Yes No
Comments _____

7.5 Is the rim of the bath between a height of 450mm-500mm? Yes No
Comments _____

7.6 If a shower is provided does it have level entry (i.e. no rim or step)? Yes No
Comments _____

7.7 Is there a clear showering area of a minimum of 800mm x 800mm? Yes No
Comments _____

7.8 Is there a seat provided within the shower area provided as well as a variety of horizontal and vertical grab rails? Yes No

Comments _____

7.9 If a door is fitted to the showering area, does it impede on the clear floor area and is it easy to use for a variety of users? Yes No

Comments _____

7.10 Is the shower control within easy reach of all users including those seated? Yes No

Comments _____

7.11 Are the taps and shower controls 'lever' operated? Yes No

Comments _____

7.12 Is there an adequate space for a wheelchair user to transfer onto the WC with a minimum width of 800mm? Yes No

Comments _____

7.13 Are grab rails fitted within the WC area to ease wheelchair transfer? Yes No

Comments _____

7.14 Is the height of the WC approximately 480mm? Yes No

Comments _____

