

**6. GUEST BEDROOMS**

6.1 Are the bedroom and bathroom on the same floor/level? Yes  No

Comments \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

6.2 Are the bedroom doors a minimum of 750mm for a wheelchair accessible bedroom and 670mm for a mobility bedroom? Yes  No

Comments \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

6.3 Are door handles, light switches, curtain pulls, and wardrobe rails, not more than 1400mm from floor level, preferably 1000mm? Yes  No

Comments \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

6.4 Are light switches and telephones next to beds within 500mm and within easy reach? Yes  No

Comments \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

6.5 Is there adequate space to transfer to at least one side of the bed from a wheelchair not being less than 800mm of space? Yes  No

Comments \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

6.6 Is there unobstructed space to allow ease of access within the room for a wheelchair user to manoeuvre? Yes  No

Comments \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

6.7 Is the top surface of the bed mattress between 450mm-540mm, preferred 480mm? Yes  No

Comments \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

6.8 Are heating controls accessible and easy to use for adjusting the temperature? Yes  No

Comments \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

6.9 Does the accessible bedroom have en-suite facilities? Yes  No

Comments \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_